


NOTE: BREAK ALL CORNERS WITH 0.015" (0.38 MM) RADIUS UNLESS OTHERWISE NOTED. STANDARD TOLERANCES TO APPLY UNLESS OTHERWISE SPECIFIED.

CUSTOMER PART No.	CUSTOMER WOLVERINE STD	WLV DIE No. WS10611	REV No. 0
DESCRIPTION .5 x 8 FRE BAR		QUOTE No. 19-1749-2	PROPOSAL No. S-12808



WALL THICKNESS $.500 \pm .009$

DATE	REV	DESCRIPTION	BY
EST. AREA	3.946	IN. ²	EST. AREA 2545.801
EST. WT.	4.619	LBS/FT.	EST. WT. 6.874
EST. PER.	16.571	IN.	EST. PER. 420.903
OUT PER.		IN.	OUT PER.
C.C.D.	8	IN.	C.C.D. 203.200
FACTOR 3.5	FINISH M/F	ALLOY & TEMP. 6101	
CKD BY	SCALE 1:2	DWN BY J.R.	DATE 11/27/19

WOLVERINE 2100 MARKET STREET
 DECATUR, AL 35816
 800-633-3972

THIS DRAWING IS NOT NECESSARILY A COPY OF YOUR ORIGINAL. PLEASE APPROVE DIMENSIONS AND TOLERANCES INDICATED. WOLVERINE ASSUMES NO RESPONSIBILITY EITHER TECHNICAL OR LEGAL FOR HAVING THIS SHAPE MADE. THE CUSTOMER AGREES TO FULLY PROTECT WOLVERINE FROM CLAIMS OF OTHERS RESULTING FROM THIS SHAPE.

SIGNED: _____ **DATE:** _____

PRINT NAME: _____